

Typical Preventative Maintenance Check List

Quarterly

The following items are inspected should be inspected in addition to those items on the Monthly Check List

Integral Quench Furnace

- Test for proper operation of high limits
- Test all other safety devices & alarms
- Inspect gas train for proper operation

Temper Furnace

- Test for proper operation of high limit
- Test all other safety devices & alarms
- Inspect gas train for proper operation

Washer

- Inspect operation of elevator and rollers
- Inspect and clean spray nozzles
- Inspect gas train for proper operation
- Test all other safety devices & alarms

Endothermic Gas Generator

- Test for proper operation of high limit
- Test all other safety devices & alarms
- Inspect gas train for proper operation